

A Precision Io Monitor System at the SRRC

C. K. Kuan, D. J. Wang, S. Y. Perng, J. R. Chen

Synchrotron Radiation Research Center (SRRC)

No. 1 R&D Road VI, Hsinchu Science-Based Industrial Park, Hsinshu 30077, Taiwan

Phone: 886-3-5780281 ext 6253; Fax: 886-3-5783890

E-Mail: ckkuan@srrc.gov.tw

Abstract

The intensity monitor (Io) system is used to monitor the beam stability at the SRRC. It includes a reflection mirror, a pinhole, a photon detector, and a precision water-cooling system. The beam stability will be increased to $\Delta I/I=0.1\%$. The mechanical stability of the system should be on the order of $0.1\text{ }\mu\text{m}$. This study considers the vibration and thermal deformation problems of the entire system. The vibration and deformation of the mirror chamber were isolated using an independent manipulator [1]. The thermal effect of the beam was reduced by the Invar material and precision water-cooling system. The beam was scanned using a $0.1\text{-}\mu\text{m}$ resolution micro-stepping motor system.

Keywords: Io monitor, mechanical stability

Presentation: Poster

- [1] D.J. Wang, T.C. Tseng, S.Y. Perng, C. K. Kuan, J.R. Chen, C.T. Chen, "A compact mirror manipulator in the SRRC beamline," J. Synch. Rad. 5 (1998) 801-803.